

# 6000/SSR/VAD Addressable Wall Mounted Sounder VAD

- LED Technology for Long Service Life
- Quick and Simple to Install
- FAST™ Addressing
- Loop Powered and Integral Short Circuit Isolator
- High Output Electronic Sounder
- 2.4 Metres (m) Mounting Height
- Adjustable 3m to 7m Room Coverage Volume
- Approved to EN54 Part 3, 17 & 23



The Protec 6000/SSR/VAD is a loop driven, addressable high intensity Visual Alarm Device (VAD) with up to 7m x 7m room coverage and a high output electronic sounder with up to 100dB(A) at 1m. Combining the two functions in one compact high efficiency design improves the aesthetic appearance and simplifies the installation of the device.

By utilising the Protec Algo-Tec<sup>™</sup> 6000 protocol, the 6000/SSR/VAD offers best in class performance in terms of flexibility, power consumption, sound output and visual indication.

The device is categorised for installation at a height of up to 2.4m and coverage of  $7m \times 7m$  W-2.4-7 adjustable down to 3m for smaller room coverage. Similarly the tone and volume options are also selectable by the control panel.

The product has a unique lens that distributes the light in a cuboid shape to achieve the required illumination of 0.4lux over the entire area in accordance with EN54 Part 23.

The design is based on LED technology for long life, reliability and low power consumption.

The 6000/SSR/VAD has a EN24-23 Type B (outdoor) + IP65 rating making the product suitable for mounting internally or externally.


Compliant with DDA legislation, this high intensity VAD warns those with hearing impairments or in noisy environments.

**Order Codes** 6000/SSR/VAD 6000/SSW/VAD


# **Technical Specification**



# **Dimensions (mm)**



# **Wiring Diagram**



# **Technical Specification**

Environment -10 to 50°C, 95% R.H (non condensation or icing)

Ingress Protection EN54-23 Type B Outdoor + IP65

Weight (excluding base) 315g
Loop Powered Yes
Voltage 18 - 28V
Loop Standby Load 0.7mA
Peak Loop Alarm Load 24mA

Mounting Height (x) 2.4 metres

Coverage(y) 7m configurable to 3m

Coverage Volume Code W-2.4-7 (117.6m³)
Flash Rate 0.5Hz white flash

Isolator Yes

Product Approval CoCP



CoCP No: 0359-CPR-0409 DoP No: PFD-CPR-0101 (SSR)

DoP No: PFD-CPR-0102 (SSW)

Relevant Standard: EN54 Part 3, 17 & 23

### **Design Guidance**

Protec VAD's have been approved to BS EN 54-23 and use the rating codes below:

W-x-y (eg W-2.4-7)

Where:

W is wall mounted

- x is the maximum height (M)
- y is the illumination diameter for the cylindrical volume (M)

BS EN 54-23 approved VAD's are approved as ceiling mounted and must provide a minimum illumination level of 0.4 lux for the stated volume

Table A: Direct Viewing

Coverage volumes for various ambient light levels (lux)

•	•
V-2.4-7	BS EN54-23 Rating
Vall	Mounting Position
6.4m x 36.4m	Less than 100 lux
0.8m x 30.8m	100 - 200 lux
2.4m x 22.4m	200 - 300 lux
6.1m x 16.1m	300 - 400 lux
2.6m x 12.6m	400 - 500 lux
.1m x 9.1m	500 - 600 lux
m x 7m	600 - 700 lux
.9m x 4.9m	700 - 800 lux
2.6m x 12.6m .1m x 9.1m m x 7m	400 - 500 lux 500 - 600 lux 600 - 700 lux


### Table B: Indirect Viewing

Coverage volumes for various ambient light levels (lux)

BS EN54-23 Rating	W-2.4-7
Mounting Position	Wall
Less than 100 lux	12.6m x 12.6m
100 - 200 lux	11.9m x 11.9m
200 - 300 lux	9.8m x 9.8m
300 - 400 lux	8.4m x 8.4m
400 - 500 lux	7m x 7m
500 - 600 lux	6.3m x 6.3m
600 - 700 lux	*
700 - 800 lux	*

Coverage volumes height, diameter length and width dimensions are in metres.

\* Where ambient light levels may, at any time, exceed 600 lux, direct viewing is preferred (CoP 001 clause 4.6.9.4)



### **Tone Options**

Bell Tone: 800Hz

Warble Tone: 990Hz(250ms), 665Hz(250ms)

Continuous Tone: 990Hz

Pulse Tone: 990Hz(500ms), Silence(500ms)

#### **Tone Volume Options**

The tone and volume are selectable at the control panel (measured at one metre): High: 100dB(A), Mid: 95dB(A), Low: 75dB(A)



Company Policy is one of continuous improvement, we reserve the right to change specification without prior notice

Protec Fire Detection Plc, Protec House, Churchill Way, Nelson, Lancashire, BB9 6RT