LPCB

This is to Certify

UniPOS Ltd 47 San Stefano Street, Pleven, Bulgaria

is authorised to use the LPCB mark in association with the product(s) listed in this certificate and appendix.

FD7160 and FD8060 Multi criteria detector

which have complied with the requirements of the following:

EN 54-5: 2000 + A1: 2002

EN 54-7: 2001 + A1: 2002 + A2: 2006

CEA 4021: July 2003

Certificate No: 1107c

Issue Number: 01

Date of Issue: 21 May 2012

Signed for and on behalf of LPCB





M McCULLAGH

LPCB is part of BRE Global Limited, Watford, WD25 9XX T: +44 (0)1923 664100 F: +44 (0)1923 664910 W: www.redbooklive.com
This certificate remains the property of BRE Global Ltd and is issued subject to terms and conditions. It is maintained and held in force through annual review and verification. To check the authenticity of this certificate, please visit www.redbooklive.com or contact us.

LPCB

Appendix to Certificate

Certificate No: 1107c

UniPOS Ltd

Certified Products

LPCB Ref. No.

FD7160

Analogue addressable combined heat & optical smoke detector

1107c/01

(7100 base)

Note:

Meets the requirements of EN 54-5: 2000 (Class A2R) & EN54-7: 2000

at default normal sensitivity setting.

FD8060

Conventional combined heat & optical smoke detector

1107c/02

(8000 base)

Note:

Meets the requirements of EN 54-5: 2000 (Class A2R) & EN54-7: 2000

at default normal sensitivity setting.

Bases

7100 standard analogue detector base 8000 standard conventional detector base

Appendix Issue No: 1107c

Page: 2 of 2

Date of Issue: 21 May 2012

Signed for and on behalf of LPCB





M McCULLAGH

LPCB is part of BRE Global Limited, Watford, WD25 9XX T: +44 (0)1923 664100 F: +44 (0)1923 664910 W: www.redbooklive.com
This certificate remains the property of BRE Global Ltd and is issued subject to terms and conditions. It is maintained and held in force through annual review and verification. To check the authenticity of this certificate, please visit www.redbooklive.com or contact us.