



BENTEL[®]
SECURITY

DECLARATION of CONFORMITY

Number: 140201337

The BENTEL SECURITY S.R.L. - Via Gabbiano, 22 - 64013 CORROPOLI (TE)

Declares that the product

FC501-L

557.200.719

FIRE PANEL FIRECLASS IT -LOW V.

complies to the following standards:

Control and indicating equipment:	EN 54-2:1997+A1:2006
Power supply equipment:	EN 54-4:1997+A1:2002+A2:2006
Safety:	EN 60950-1:2006+A11:2009
Emissions:	EN 61000-6-3:2007+A1:2011
Immunity:	EN 50130-4:2011
Telecommunications terminal equipment:	ETSI ES 203 021-1 V2.1.1:2005 ETSI ES 203 021-2 V2.1.2:2006 ETSI ES 203 021-3 V2.1.2:2006

and thereby, complies the ESSENTIAL REQUISITES of DIRECTIVES:

*89/106/CEE
2006/95/CE
2004/108/CE
2011/65/EU
1999/5/CE*

Notified Body:

*IMQ S.p.A Via Quintiliano, 43 -
ITALIA 20138 Milano*

Corropoli (TE), 14/02/2014

CE 0051

Certificate: 0051-CPR-406

**Il consigliere delegato
Andrea Cotichelli**