



BENTEL[®]
SECURITY

DECLARATION of CONFORMITY

The BENTEL SECURITY S.R.L. - Via Gabbiano, 22 - 64013 CORROPOLI (TE)
Declares that the product

FC520

PFNCFBL3FC520

ANALOGUE FIRE-PANEL 2LOOP BENTEL FC520

complies to the following standards:

Control and indicating equipment:	EN 54-2:1997+A1:2006
Power supply equipment:	EN 54-4:1997+A1:2002+A2:2006
Safety:	EN 60950-1:2006+A11:2009
Emission:	EN 61000-6-3:2007
Immunity:	EN 50130-4:1995+A1:1998+A2:2003

and thereby, complies the ESSENTIAL REQUISITES of DIRECTIVES

89/106/CEE
2006/95/CE
2004/108/CE

Notified Body:

IMQ S.p.A
Via Quintiliano, 43 - 20138 Milano
ITALIA

Corropoli (TE), 13/01/2010

CE 0051

**Il consigliere delegato
Andrea Cotichelli**

Certificato: 0051-CPD-0191