



# Certificate of Continued Compliance 202350097/AA/01



Issued 08-07-2024  
Expiry date 08-07-2028

Replaces 202350097/AA/00  
Page 1 / 4

In compliance with the procedure specified in the **Alarm Components Scheme**, Kiwa FSS products declares that the stated alarm equipment complies with the technical standards and specifications as listed in Annex 2 of this certificate. This certificate relates to an ISO/IEC 17067 scheme type 5 registration including biennial factory inspection and yearly market surveillance.

Product description: Hybrid control panel  
Trademark: Climax  
Type designation: HYB-LITE-QT-E-SF1  
Hardware / Software: V1.0J (V1.0) / HYB-LITE-QT-E alarm-0.0.2.29D See Annex  
Variants: 3

Placed on the market under the name or trademark of:

Name of the manufacturer: Climax Technology Co., Ltd.  
Address: No. 258, Hsin Hu 2nd Road, Neihu District  
City: 114 Taipei City  
Country: Taiwan

This certificate is granted to:

Name of the certificate holder: Climax Technology Co., Ltd.  
Address: No. 258, Hsin Hu 2nd Road, Neihu District  
City: 114 Taipei City  
Country: Taiwan

Ron Scheepers  
Managing director

*This certificate has THREE Annexes.*

Kiwa Nederland B.V.  
Kiwa FSS Products  
Wilmsdorf 50  
Postbus 137  
7300 AC Apeldoorn  
The Netherlands

<https://www.kiwa.com/nl/en/specials/fire-safety-and-security>



## Remarks and observations

The following conditions are applicable:

Security grade: 2  
Environmental class: II  
Equipment class: Fixed  
Power supply type: A  
ATS class: DP1

This equipment can be applied in EN 50131-1 compliant systems up to and including security grade 2.  
Electromagnetic emission and safety aspects are not covered by this certificate.

Factory location:  
Climax Technology Co., Ltd.  
No. 258, Xinhua 2nd. Road, Neihu District  
Taipei City  
Taiwan

Product inspection location:  
Deventer KontraktLogistik GmbH c/o Climax Deutschland GmbH  
Hüttenstraße 100  
Kerpen  
Germany

Documentation lodged for this Certificate of Continued Compliance

Test Reports:

- Kiwa Nederland B.V.: P000227515-001-Ver 1.00, 8 July 2024
- Kiwa Nederland B.V.: P000227515-002-Ver 1.00, 8 July 2024

Product Documentation:

- Assembly drawings
- Bill of material / Parts list
- Electronic schematics
- Manual
- Internal / external photos
- Label and label placement

Technical Standards and Specifications

The product shows no non-compliances with:

EN 50131-3	March, 2009
EN 50131-5-3	March, 2017

Applied Standards

EN 50130-5	June, 2011
EN 50136-2	August, 2013
EN 50131-10	June, 2014
EN 50131-6+A1	June, 2021
EN 50136-1+A1	November, 2018
EN 50131-1+A1+A2+A3	June, 2020
EN 50130-4+A1	October, 2014

The product as described in this certificate includes the following type designations

- Product description: Hybrid control panel Climax
  - Trademark: HYB-LITE-QT-E-SF1
  - Type designation: V1.0J (V1.0)
  - Hardware version: HYB-LITE-QT-E-0.0.2.29D
  - Software version:
- 
- Product description: Hybrid control panel Climax
  - Trademark: HYB-LITE-QT-E-SF1
  - Type designation: V1.0J (V2.0)
  - Hardware version: HYB-LITE-QT-E-0.0.2.29D
  - Software version: