



Certificate of Continued Compliance 232350075/AA/00



Issued 02-08-2024
Expiry date 02-08-2028

Replaces
Page 1 / 4

In compliance with the procedure specified in the **Alarm Components Scheme**, Kiwa FSS products declares that the stated alarm equipment complies with the technical standards and specifications as listed in Annex 2 of this certificate. This certificate relates to an ISO/IEC 17067 scheme type 5 registration including biennial factory inspection and yearly market surveillance.

Product description: Wired PIR Motion Sensor
Trademark: Climax
Type designation: IR-35-BUS
Hardware / Software: V1.1 / IR-35-R2-BUS_BL_C10

Placed on the market under the name or trademark of:

Name of the manufacturer: Climax Technology Co., Ltd.
Address: No. 258, Hsin Hu 2nd Road, Neihs District
City: 114 Taipei City
Country: Taiwan

This certificate is granted to:

Name of the certificate holder: Climax Technology Co., Ltd.
Address: No. 258, Hsin Hu 2nd Road, Neihs District
City: 114 Taipei City
Country: Taiwan

Ron Scheepers
Managing director

This certificate has THREE Annexes.

Kiwa Nederland B.V.
Kiwa FSS Products
Wilmsdorf 50
Postbus 137
7300 AC Apeldoorn
The Netherlands

<https://www.kiwa.com/nl/en/specials/fire-safety-and-security>



Remarks and observations

The following conditions are applicable:

Security grade: 2

Environmental class: II

Equipment class: Fixed

This equipment can be applied in EN 50131-1 compliant systems up to and including security grade 2.

Factory location:

Climax Technology Co., Ltd.

No. 258, Hsin Hu 2nd Road, Neihu District

Taipei City

Taiwan

Product inspection location:

Deventer KontraktLogistik GmbH c/o Climax Deutschland GmbH

Hüttenstraße 100

Kerpen

Germany

Documentation lodged for this Certificate of Continued Compliance

Test Reports:

- Kiwa Nederland B.V.: P000332468-001-ver.1.00, 03 May 2024
- Kiwa Nederland B.V.: P000292501-001-ver.1.00, 15 December 2023

Product Documentation:

- Assembly drawings
- Bill of material / Parts list
- Electronic schematics
- Manual
- Internal / external photos
- Label and label placement

Technical Standards and Specifications

The product shows no non-compliances with:

EN 50131-2-2	December, 2021
--------------	----------------

Applied Standards

EN 50130-5	June, 2011
EN 50130-4+A1	October, 2014
EN 50131-1+A1+A2+A3	June, 2020

The product as described in this certificate includes the following type designations

- | | |
|------------------------|-------------------------|
| - Product description: | Wired PIR Motion Sensor |
| - Trademark: | Climax |
| - Type designation: | IR-35-BUS |
| - Hardware version: | V1.1 |
| - Software version: | IR-35-R2-BUS_BL_C10 |