

CE CERTIFICATE

Notified Body No. 0370

No. **0370-CPR-3636**

CERTIFICATE OF CONSTANCY OF PERFORMANCE

In compliance with Regulation 305/2011/EU of the European Parliament and of the Council of 9 March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product:

FIRE DETECTION AND FIRE ALARM SYSTEM.

- **PART 2:** CONTROL AND INDICATING EQUIPMENT.
- **PART 4:** POWER SUPPLY EQUIPMENT.

MODELS: **ONE MINI_AP; ONE MINI LIGHT_AP; ONE MINI SUPERLIGHT_AP**

Place on the market under the name of:

TELEDATA, S.R.L.

VIA GIULIETTI, 8
20132 MILANO (ITALY)

And produced in the manufacturing plant:

VIA BRESCIA 24/G
20063 CERNUSCO SUL NAVIGLIO, MILANO (ITALY)

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standards

**EN 54-2:1997, EN 54-2:1997/AC:1999, EN 54-2:1997/A1:2006; EN 54-4:1997,
EN 54-4:1997/AC:1999, EN 54-4:1997/A1:2002, EN 54-4:1997/A2:2006**

under system 1 are applied and that **the product fulfils all the prescribed requirements set out above.**

This certificate was first issued on 27th September 2019 and will remain valid as long as the test methods and/or factory production control requirements included in the harmonised standard, used to assess the performance of the declared characteristics, do not change, and the product, and the manufacturing conditions in the plant are not modified significantly. It is confirmed on 26th March 2021.

The monitoring assessment will be done before 28th February 2022

Bellaterra, 26th March 2021


LGAI Technological Center, S.A.

Xavier Ruiz Peña
Managing Director, Product Conformity B.U.

This document is not valid without its technical annex; whose number coincides with that of the certificate.

You can check the validity of this certificate on our website: www.appluslaboratories.com/certified_products



0370-CPR-3636

Annexes according to **EN 54-2:1997, EN 54-2:1997/AC:1999, EN 54-2:1996/A1:2006**

ESSENTIAL CHARACTERISTICS	CLAUSES IN THIS EUROPEAN STANDARD	MANDATED LEVEL(S) OR CLASS(ES)
General requirements	4.	PASS
General requirements for indications	5.	PASS
The quiescent condition	6.	PASS
The fire alarm condition	7.	PASS
Reception and processing of fire signals (see also annex C)	7.1	PASS
Output of the fire alarm condition	7.7	PASS
Fault warning condition (see also annex F)	8.	PASS
Fault signals from points (option with requirements)	8.3	PASS
Total loss of the power supply (option with requirements)	8.4	PASS
Disabled condition	9.	PASS
Disabling of addressable points (option with requirements)	9.5	PASS
Test condition (option with requirements)	10.	PASS
Standardized input/output interface (option with requirements –see also annex G)	11.	NA
Design requirements	12.	PASS
Additional design requirements for software controlled control and indicating equipment	13.	PASS
Marking	14.	PASS
Cold (operational)	15.4	PASS
Damp heat, steady state (operational)	15.5	PASS
Impact (operational)	15.6	PASS
Vibration, sinusoidal (operational)	15.7	PASS
Electromagnetic Compatibility (EMC)	15.8	PASS
Supply voltage variation (operational)	15.13	PASS
Damp heat, steady state (endurance)	15.14	PASS
Vibration, sinusoidal (endurance)	15.15	PASS

PASS; NPD = No Performance Determined, NA = Not Apply

0370-CPR-3636

Annexes according to **EN 54-4:1997, EN 54-4: 1997/AC:1999, EN 54-4: 1997/A1:2002, EN 54-4: 1997/A2:2006**

ESSENTIAL CHARACTERISTICS	CLAUSES IN THIS EUROPEAN STANDARD	MANDATED LEVEL(S) OR CLASS(ES)
General requirements	4.	PASS
Functions	5.	PASS
Materials, design and manufacture	6.	PASS
Documentation	7.	PASS
Marking	8.	PASS
Cold (operational)	9.5	PASS
Damp Heat, steady state (operational)	9.6	PASS
Impact (operational)	9.7	PASS
Vibration, sinusoidal (operational)	9.8	PASS
Electrostatic discharges (operational)	9.9	PASS
Damp heat, steady state (endurance)	9.14	PASS
Vibration, sinusoidal (endurance)	9.15	PASS

PASS; NPD = No Performance Determined, NA = Not Apply