



CERTIFICATE

Notified Body No. 0370

No

0370-CPR-3640

CERTIFICATE OF CONSTANCY OF PERFORMANCE

In compliance with Regulation 305/2011/EU of the European Parliament and of the Council of 9 March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product:

FIRE DETECTION AND FIRE ALARM SYSTEM.

PART 5: HEAT DETECTORS. POINT DETECTORS

PART 17: SHORT-CIRCUIT ISOLATORS

MODEL: ONEDETECTOR2 AP

Place on the market under the name of:

TELEDATA, S.R.L.

VIA GIULIETTI, 8 20132 MILANO (ITALY)

And produced in the manufacturing plant:

VIA BRESCIA 24/G 20063 CERNUSCO SUL NAVIGLIO, MILANO (ITALY)

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standards

EN 54-5:2000, EN 54-5:2000/A1:2002; EN 54-17:2005, EN 54-17:2005/AC:2007

under system 1 are applied and that the product fulfils all the prescribed requirements set out above.

This certificate was first issued on 27th September 2019 and will remain valid as long as the test methods and/or factory production control requirements included in the harmonised standard, used to assess the performance of the declared characteristics, do not change, and the product, and the manufacturing conditions in the plant are not modified significantly. It is confirmed and modified on 26th March 2021.

The monitoring assessment will be done before 28th February 2022

Bellaterra, 26th March 2021

Applus[®]
LGAI Technological Center, S.A.

Xavier Ruiz Peña

Managing Director, Product Conformity B.U.

This document is not valid without its technical annex; whose number coincides with that of the certificate.

You can check the validity of this certificate on our website: www.appluslaboratories.com/certified products





www.appluslaboratories.com



Technical Annex Ed. 2 26/03/2021

0370-CPR-3640

Annexes according to **EN 54-5:2000, EN 54-5:2000/A1:2002**

| ESSENTIAL CHARACTERISTICS | CLAUSES IN THIS EUROPEAN STANDARD | MANDATED LEVEL(S) OR CLASS(ES) |
|---|--------------------------------------|--------------------------------------|
| Classification | 4.2 | A1/B PASS |
| Position of heat sensitive elements | 4.3 | PASS |
| Individual alarm indication | 4.4 | PASS |
| Connection of ancillary devices | 4.5 | PASS |
| Monitoring of detachable detectors | 4.6 | PASS |
| Manufacturer's adjustments | 4.7 | PASS |
| On-site adjustment of response behaviour | 4.8 | PASS |
| Marking | 4.9 | PASS |
| Data | 4.10 | PASS |
| Additional requirements for software controlled detectors | 4.11 | PASS |
| Directional dependence | 5.2 | PASS |
| Static response temperature | 5.3 | PASS |
| Response times from typical application temperature | 5.4 | PASS |
| Response times from 25 °C | 5.5 | NA |
| Response times from high ambient temperature (dry heat operational) | 5.6 | PASS |
| Variation in supply parameters | 5.7 | NA |
| Reproducibility | 5.8 | PASS |
| Cold (operational) | 5.9 | PASS |
| Dry heat (endurance) | 5.10 | NA |
| Damp heat, cyclic (operational) | 5.11 | PASS |
| Damp heat, steady state (endurance) | 5.12 | PASS |
| Sulfur dioxide (SO2) corrosion (endurance) | 5.13 | PASS |
| Shock (operational) | 5.14 | PASS |
| Impact (operational) | 5.15 | PASS |
| Vibration, sinusoidal (operational) | 5.16 | PASS |
| Vibration, sinusoidal (endurance) | 5.17 | PASS |
| Electromagnetic compatibility (EMC), immunity tests (operational) | 5.18 | PASS |
| Test for suffix S detectors | 6.1 | NA |
| Test for suffix R detectors | 6.2 | NPD |

PASS; NPD = No Performance Determined, NA = Not Apply

www.appluslaboratories.com



Technical Annex Ed. 2 26/03/2021

0370-CPR-3640

Annexes according to EN 54-17:2005, EN 54-17:2005/AC:2007

| ESSENTIAL CHARACTERISTICS | CLAUSES IN THIS EUROPEAN STANDARD | MANDATED LEVEL(S) OR CLASS(ES) |
|---|--------------------------------------|--------------------------------------|
| Compliance | 4.1 | PASS |
| Integral status indication | 4.2 | NA |
| Connection of ancillary devices | 4.3 | NA |
| Monitoring of detachable short-circuit isolators | 4.4 | NA |
| Manufacturer's adjustments | 4.5 | PASS |
| On-site adjustments | 4.6 | NA |
| Marking | 4.7 | PASS |
| Data | 4.8 | PASS |
| Additional requirements for software controlled short-circuit isolators | 4.9 | PASS |
| Reproducibility | 5.2 | PASS |
| Variation in supply voltage | 5.3 | PASS |
| Dry heat (operational) | 5.4 | PASS |
| Cold (operational) | 5.5 | PASS |
| Damp heat, cyclic (operational) | 5.6 | PASS |
| Damp heat, steady state (endurance) | 5.7 | PASS |
| Sulphur dioxide (SO2) corrosion (endurance) | 5.8 | PASS |
| Shock (operational) | 5.9 | PASS |
| Impact (operational) | 5.10 | PASS |
| Vibration, sinusoidal (operational) | 5.11 | PASS |
| Vibration, sinusoidal (endurance)) | 5.12 | PASS |
| Electromagnetic Compatibility (EMC), Immunity tests (operational) | 5.13 | PASS |

PASS; NPD = No Performance Determined, NA = Not Apply

| Ancillary equipment | ONEBASE |
|---------------------|---------|
|---------------------|---------|