



Head Office:

Via Brescia 24 G  
20063 Cernusco sul Naviglio (MI)  
Tel. + 39 02.27.20.13.52  
E-mail: info@teledata-i.com

[www.teledata-i.com](http://www.teledata-i.com)

## **EC - Declaration of performance**

**N.51/2019**

According to Regulation EU No. 305/2011

- 1- Code of the product / type: ONEMINI\_AP, ONEMINILIGHT\_AP, ONEMINISUPERLIGHT\_AP.
- 2- Type number: ONEMINI\_AP, ONEMINILIGHT\_AP, ONEMINISUPERLIGHT\_AP..

Description: **Addressable Fire Alarm Control Panel**

- 3- Intended use or uses of the construction product, in accordance with the applicable harmonized technical specification, as foreseen by the manufacturer:

**Fire detection and fire alarm systems installed in and around buildings**

- 4- Manufacturer: **Teledata s.r.l.**,  
operational headquarters : **Via Brescia, 24/G Cernusco S/N - 20063 Milano**  
registered office : **Via Giulietti, 8, 20132 Milano, Italy**
- 5- Trading Company: **Teledata s.r.l.**,  
operational headquarters : **Via Brescia, 24/G Cernusco S/N - 20063 Milano**  
registered office : **Via Giulietti, 8, 20132 Milano, Italy**
- 6- System of assesment: **System 1**
- 7- Notify Body: **LGAI Technological Center, S.A. (APPLUS) Campus UAB- Ronda de la Font del Carme s/n 08193 Bellaterra ( Barcellona)**

Notify Body Number: **0370**

EC Certificate n°: **0370 – CPR – 3636**





## 8- Declared Performance:

Annexes according to **EN 54-2:1997, EN 54-2:1997/AC:1999, EN 54-2:1996/A1: 2006**

ESSENTIAL CHARACTERISTICS	CLAUSES IN THIS EUROPEAN STANDARD	MANDATED LEVEL(S) OR CLASS(ES)
General requirements	4.	PASS
General requirements for indications	5.	PASS
The quiescent condition	6.	PASS
The fire alarm condition	7.	PASS
Reception and processing of fire signals (see also annex C)	7.1	PASS
Output of the fire alarm condition	7.7	PASS
Fault warning condition (see also annex F)	8.	PASS
Fault signals from points (option with requirements)	8.3	PASS
Total loss of the power supply (option with requirements)	8.4	PASS
Disabled condition	9.	PASS
Disabling of addressable points (option with requirements)	9.5	PASS
Test condition (option with requirements)	10.	PASS
Standardized input/output interface (option with requirements –see also annex G)	11.	NA
Design requirements	12.	PASS
Additional design requirements for software controlled control and indicating equipment	13.	PASS
Marking	14.	PASS
Cold (operational)	15.4	PASS
Damp heat, steady state (operational)	15.5	PASS
Impact (operational)	15.6	PASS
Vibration, sinusoidal (operational)	15.7	PASS
Electromagnetic Compatibility (EMC)	15.8	PASS
Supply voltage variation (operational)	15.13	PASS
Damp heat, steady state (endurance)	15.14	PASS
Vibration, sinusoidal (endurance)	15.15	PASS





Annexes according to EN 54-4:1997, EN 54-4: 1997/AC:1999, EN 54-4:1997/A1:2002, EN 54-4: 1997/A2:2006

ESSENTIAL CHARACTERISTICS	CLAUSES IN THIS EUROPEAN STANDARD	MANDATED LEVEL(S) OR CLASS(ES)
General requirements	4.	PASS
Functions	5.	PASS
Materials, design and manufacture	6.	PASS
Documentation	7.	PASS
Marking	8.	PASS
Cold (operational)	9.5	PASS
Damp Heat, steady state (operational)	9.6	PASS
Impact (operational)	9.7	PASS
Vibration, sinusoidal (operational)	9.8	PASS
Electrostatic discharges (operational)	9.9	PASS
Damp heat, steady state (endurance)	9.14	PASS
Vibration, sinusoidal (endurance)	9.15	PASS

PASS; NPD = No Performance Determined, NA = Not Apply

9- The performance of the product identified in points 1 and 2 is in conformity with the declared performance in point 8.

This declaration of performance is issued under the sole responsibility of the manufacturer identified in point 4:

Your Faithfully.

October 24th , 2019

Luca SEBASTIO  
Quality Manager

